


## Material Test Report

**Client:** Stephen Elliott  
 Urban Resources Pty Ltd  
 PO Box 739  
 Como WA 6952

**Project:** Smirk Road Lot 6

Date of Issue:  
 THIS DOCUMENT SHALL NOT BE REPRODUCED EXCEPT IN FULL

Sample Details		Other Test Results			
<b>Sample ID:</b>	SMI611017	<b>Description</b>	<b>Method</b>	<b>Result</b>	<b>Limits</b>
<b>Field Sample:</b>		Clay and Fine Silt (%)	AS 1141.33	20	15 – 35
<b>Date Sampled:</b>	24/11/2011	Moisture Content (%)	AS 1289.2.1.1	2.6	
<b>Source:</b>	Stockpile				
<b>Material:</b>	Plaster Sand				
<b>Specification:</b>	Plaster Sand				
<b>Sampling Method:</b>	Hand Sampling [AS1141.3.1]				
<b>Location:</b>					
<b>GPS Easting:</b>					
<b>GPS Northing:</b>					



**Comments**  
 N/A